

STATE OF OHIO
DEPARTMENT OF ADMINISTRATIVE SERVICES
GENERAL SERVICES DIVISION
OFFICE OF PROCUREMENT SERVICES
4200 SURFACE ROAD, COLUMBUS, OH 43228-1395

REQUIREMENTS CONTRACT: EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR

CONTRACT No.: OT905108

EFFECTIVE DATES: 03/01/08 to 12/31/10
Renewal through 05/31/11*

The Department of Administrative Services has accepted bids submitted in response to Invitation to Bid No. OT905108 that opened on 12/19/07. The evaluation of the bid response(s) has been completed. The bidder(s) listed herein have been determined to be the lowest responsive and responsible bidder(s) and have been awarded a contract for the items(s) listed. The respective bid response, including the [Terms and Conditions for Bidding, Standard Contract Terms and Conditions, and Supplemental Contract Terms and Conditions](#), special contract terms & conditions, any bid addenda, specifications, pricing schedules and any attachments incorporated by reference and accepted by DAS become a part of this Requirements Contract.

This Requirements Contract is effective beginning and ending on the dates noted above unless, prior to the expiration date, the Contract is renewed, terminated or cancelled in accordance with the Contract Terms and Conditions.

This Requirements Contract is available to OHIO DEPARTMENT OF PUBLIC SAFETY, DIVISIONS AS LISTED HEREIN, as applicable.

Agencies are eligible to make purchases of the listed supplies and/or services in any amount and at any time as determined by the agency. The State makes no representation or guarantee that agencies will purchase the volume of supplies and/or services as advertised in the Invitation to Bid.

SPECIAL NOTE: State agencies may make purchases under this Requirements Contract up to \$2500.00 using the state of Ohio payment card. Any purchase that exceeds \$2500.00 will be made using the official state of Ohio purchase order (ADM-0523). Any non-state agency, institution of higher education or Cooperative Purchasing member will use forms applicable to their respective agency.

Questions regarding this and/or the Requirements Contract may be directed to:

Lauren Brown
Lauren.Brown@das.state.oh.us

This Requirements Contract and any Amendments thereto are available from the DAS website at the following address:

<http://www.ohio.gov/procure>

* Renewal effective 01/31/11 through 05/31/11.

Signed: _____
Robert Blair, Director Date

TABLE OF CONTENTS

<u>CLAUSES</u>	<u>PAGE NO.</u>
Award	3
Evaluation	3
Usage Reports	3
Specifications	4-11

<u>CONTRACT ITEMS</u>	
Appendix A	19-26
Appendix B	27
Contractor Index	18
Price Schedule	12-16

SPECIAL CONTRACT TERMS AND CONDITIONS

WHERE APPLICABLE, THE FOLLOWING TERMS AND CONDITIONS SUPERSEDE ANY STANDARD TERMS AND CONDITIONS SHOWN IN THIS BID.

DELIVERY AND ACCEPTANCE: Services will be performed as set forth in the Contract and in accordance with paragraphs S-8, S-9, and S-10 of the SUPPLEMENTAL CONTRACT TERMS AND CONDITIONS. The location of performance will be noted on the purchase order issued by the participating agency. Payment for services rendered will occur upon the inspection and written confirmation by the ordering agency that the services provided conform to the requirements set forth in the Contract. Unless otherwise provided in the Contract, payment shall be conclusive except as regards to latent defects, fraud, or such gross mistakes as amount to fraud.

SITE VISIT: Prior to submitting their bid response, the Bidder should visit the agency (ies) they are bidding in order to survey the facility(s) and to become familiar with the requirements of the bid. The Bidder must contact each facility to schedule an appointment. The contact person for each facility will be the OSHP Post Commander, or the listed contact person. See Appendix A for phone numbers. Once a contract is awarded, failure of the Bidder to have requested a site visit to become familiar with the facility and requirements of the bid will be insufficient reason to support any request to be released from the contract.

CONTRACT COST ADJUSTMENTS: During the term of this contract, there may be an increase/decrease in the number of like generators and associated systems to be serviced due to program changes and/or building destruction/construction. The successful Bidder agrees to adjust the service schedule to incorporate any increases/decreases in the number of units to be serviced. Cost for service of any added units shall be at the rates shown in the Price Schedule.

SUBCONTRACTING: The awarded Contractor shall be solely responsible for the contract. All work must be done by direct employees of the awarded Contractor. The awarded Contractor shall not engage a subcontractor for any work performed in conjunction with this contract without the prior written approval of (DPS-OSHP/DAS).

MATERIAL SAFETY DATA SHEET: The Contractor shall provide a Material Safety Data Sheet (MSDS) for any hazardous chemical that he brings onto the facility property for the performance of this contract. The MSDS shall verify the Contractor's compliance with OSHA's Hazard Communications Standard 29 CFR 1910.1200. The MSDS shall be given to the facility contact person prior to use of the hazardous chemical on the facility property.

BUSINESS REFERENCES: All Bidders shall submit with their bid, a list of at least three (3) companies and/or organizations with which they have had recent (within two [2] years) generator service contracts. This list shall include the name and phone number of a contact person who will be familiar with the Bidder's job performance. The state may elect to verify the Bidder's experience based upon the list of business references submitted and any other sources which the state deems appropriate.

AWARD: There will be one low lot total award for each Contract District made to the lowest responsive and responsible Bidder meeting all bid specifications and requirements listed herein. Bidders may quote on 1, 2, 3, 4, or 5 Contract Districts.

EVALUATION: To determine the low lot total price of each Contract District, the state will add the following:

- A. The sum of the product of the Flat Rate Cost for Scheduled Service for each service year times the number of generators in that Contract District.
- B. The sum of the yearly totals for the Emergency Service scenario listed for that Contract District.

USAGE REPORTS: Every twelve (12) months the Contractor must submit a report (written or on disk) indicating sales generated by this contract. The report shall list usage by customer, by line item, showing the quantities/dollars generated by this contract. The report shall be forwarded to the Office of State Purchasing, 4200 Surface Road, Columbus, Ohio 43228-1395, Attn: Harry Graham.

SPECIFICATIONS

I. SCOPE:

This Invitation to Bid (ITB), and any resultant contract, are issued to obtain annual inspection, testing, preventive maintenance and repair services for emergency power generators and associated systems owned by the State of Ohio, Department of Public Safety, State Highway Patrol (OSHP) and the Emergency Management Agency (EMA). These services shall be in accordance with the applicable generator manufacturer's recommendations and as specified herein. The generators are located at OSHP Posts, remote sites and buildings in the metropolitan Columbus area as listed in Appendix A. For this Bid, and any resultant contract, the State has been divided into five contract districts: Northwest, Northeast, Southwest, Southeast and Central. Award will be by Contract District. Bidders may quote on one, two, three, four or five districts. The contract term is two (2) years. The Index No. of this contract was formerly DHP003D.

II. CLASSIFICATION:

Generators that will require service are of various brands and types. Specific information about these units is shown in Appendix A. There have been deletions from this master list that caused breaks in the numerical sequence of generator numbers.

III. GENERAL REQUIREMENTS:

- A. Contractor's work teams used for this contract shall consist of one or more certified technicians. The Contractor should make every effort to ensure that technician site assignments remain constant during the life of the contract.
- B. Inspection, testing, and maintenance service of the generators shall be performed annually, and shall be in accordance with the generator manufacturer's recommendations. OSHP Facility Management will determine the timeline/window for the inspections (example: February, March, April). Elapsed time between scheduled annual service visits at each facility or remote site shall be within a two (2) week period of the twelve (12) month scheduled visit. Deviation from this schedule may be cause for cancellation of this contract with the affected facility(s).

IV. DOCUMENTATION AND REFERENCES:

- A. For this contract, the Contractor shall employ trained, experienced and certified generator service technicians. The Contractor shall only assign technicians to this contract who have a minimum of three (3) years experience in inspection, testing and maintenance of generators. Resumes of these technicians shall be provided with the ITB. Resumes shall include confirmation of education/training and also any certifications held by the technician.
- B. Bidder shall provide evidence of maintaining and repairing generators and associated systems. Bidder shall give names, addresses and telephone numbers of three (3) customers for whom he has provided such services within the previous two years.

V. CONTACT PERSONS:

- A. Unless stated otherwise, the contact person for each OSHP Post shall be the Post Commander or appropriate Facility office for EMA, ODPS (General Headquarters, Centre School, Alum Creek Facility). See Appendix A. Otherwise, the contact person shall be the Facility Management Commander (614-466-8627) or the Technology and Communications Services Commander (614-466-8785).
- B. During the term of this contract, each party shall notify the other appropriate parties of changes in names, etc., of the contact person.

VI. TERMS OF PAYMENT:

All non-scheduled or emergency service shall be invoiced to the facility only after said work is completed. Contractor shall include description of work performed, and Contract Number on all statements and invoices.

SPECIFICATIONS (Cont'd.)

VII. CHARGES FOR SCHEDULED SERVICE:

Charges for Scheduled Service at all locations shall be at the Flat Rate listed in the Price Schedule for the specific service year. The Flat Rate quoted by each Bidder should include all labor and travel, and all parts, fluids and supplies normally replaced during annual service.

VIII. CONTRACTOR PERFORMANCE:

- A. The Contractor shall perform the inspections, testing (non-load and full-load), and preventive maintenance service of the generators and associated systems at the OSHP and EMA locations on an annual scheduled basis as specified herein during the term of this contract. NOTE: No load bank testing is required on portable generators. Maintenance on portable generators will be performed on an as-needed basis, at the request of the OSHP.
- B. The Contractor shall notify the OSHP Post Commander and the OSHP Facility Management Commander not less than two (2) days prior to each inspection of that location. For the other units included in this contract, the Contractor shall notify the listed contact person not less than two (2) days prior to each inspection.
- C. Any inspections required to comply with State and Federal regulations in effect during the contract period shall be included in the bid price.
- D. The Contractor shall maintain a complete set of records of the inspections, including, but not limited to, inspection dates, equipment checked, pieces of equipment replaced, technicians involved, system operation and performance status, recommendations for improvement, etc. One copy of the records shall be provided to the Post Commander, when applicable, and one copy shall be provided to the appropriate Facility Management office. Records provided shall include a completed copy of the OSHP Emergency Generator Checklist, which is shown as Appendix B.
- E. Following completion of each inspection, the Contractor's team shall review with the Post Commander, the details of the work just completed and the condition of the system, plus any recommendations for necessary repairs or improvements to the system. Quotations for recommended repairs shall be sent to the Post Commander and/or the respective Facility Management office within ten (10) days from the OSHP's request.
- F. Within two (2) weeks following an inspection, the Contractor shall file a written inspection report with the Post Commander and/or the appropriate Facility Management office.

IX. HOURS OF SERVICE:

- A. Unless noted otherwise herein, scheduled service shall be: 7:30 a.m. until 4:30 p.m., Monday through Friday, except State holidays.
- B. Emergency service shall consist of having the Contractor's certified technician arrive at the applicable generator location (for OSHP units, that will be the OSHP post) within six (6) hours after notification by the OSHP Post, or the applicable contract person. Pagers, message machines or other mechanical recording devices, and answering machines are acceptable as a communication center. Any situation that results in a non-operational power generator will be considered an "Emergency" by OSHP and EMA.
- C. Emergency Service shall be charged as an additional cost item at the rate quoted in the ITB. Bidders shall indicate the mileage charge (one-way) for this service during normal working hours on weekdays and for Overtime service after normal working hours or on weekends or holidays. The Emergency Service hourly charges shall only be applicable to time on-site.
- D. The Contractor shall be capable of responding at any time of the day or night upon notification by telephone that a situation exists where a shut-down or emergency has occurred. The Contractor must have adequate personnel available to provide emergency services twenty-four (24) hours per day, three hundred sixty-five (365) days per year.

SPECIFICATIONS (Cont'd.)

- E. Invoices for emergency services shall be forwarded to the Post Commander or appropriate facility office and shall contain a complete list of material and supplies required, labor and travel charges (one-way mileage only; travel time will not be reimbursed), and a written report covering the details of the emergency service. NOTE: Maintenance and repairs on portable generators, when requested by OSHP, shall be charged at the Emergency rate.
- F. One way mileage: All mileage reimbursement will be the lesser of: (1) actual mileage from point of departure to ODPS site location, or (2) mileage from Contractor's nearest service center to ODPS site location. The Contractor must bill for mileage at the rates quoted in this ITB and any resultant contract.
- G. Emergency Response. Any additional emergency work will be performed upon request by Facility or Facility Management. If the estimated cost of the repair(s) exceeds \$1000.00, that repair(s) will first need to be approved by the appropriate facility office.
- H. Inspections.
 - 1. OSHP. With the exception of portable generators, the contract portion applicable to OSHP Posts and remote sites shall include the following annual services:
 - Check coolant levels.
 - Analyze coolant for proper antifreeze percentages and adjust accordingly.
 - Inspect cooling system hoses.
 - Tighten hose clamps as needed.
 - Clean fuel filter.
 - Clean air cleaner.
 - Service belts as required.
 - Check engine heater operation.
 - Check generator set for fuel, oil, and coolant leaks.
 - Check air intakes and outlets.
 - Check transfer tank operation.
 - Drain exhaust line.
 - Check battery charger operation and charge rate.
 - Check battery electrolyte levels and specific gravity.
 - Check generator output voltage and adjust as necessary.
 - Emergency system operation with load transfer.
 - Emergency system operation without load transfer.
 - Frequency check / governor adjustment.
 - Check transfer switch and accessory operation.
 - Check engine alternator charge rates.
 - Check engine and generator gauge and indicator operation.
 - Check generator set controller operation including shut-down functions and emergency stop.
 - Lube, oil and filter change.
 - Fuel filter change
 - Engine tune-up with parts
 - Four hour external resistive load bank test: (two hours at 50%, one hour at 75%, one hour at 100%)
 - 2. EMA. All lubricants, ball bearings, brushes, brush holders, commutator, cooling screens, alternator, connections, insulation, shunt trip, mainline circuit breaker, belts, hoses, spark plugs, Automatic Transfer Switches, Indicator lights and overall condition of the unit shall be inspected. The Contractor shall also perform the 80% 4 hour load bank testing recording items such as (but not limited to) oil pressure, water temperature, voltage, voltage frequency. The load bank testing shall be performed with no interruption of normal power supply and only during the hours specified by each site. Oil Analysis upon request. Hours of service at this location are 7:00 A.M. – 3:30 P.M.

SPECIFICATIONS (Cont'd.)

3. GHQ (Shipley Mega Generator) and Center School

The Shipley Mega Generator requires the services of a Certified Cummins Technician.

Indicator lights and overall condition of the unit shall be inspected. The Contractor shall also perform an annual 80% 4-hour load bank testing and shall record items including, but not limited to, oil pressure, water temperature, voltage, voltage frequency. The load bank testing shall be performed with no interruption of normal power supply and only during the hours specified by each site. This location shall receive four (4) inspections per year: May, November, February, August (one [1] Annual, one [1] Semi-Annual, and two [2] quarterly inspections). Oil Analysis shall be accomplished per Preventive Maintenance task in Section X below.

4. Alum Creek Facility.

Overall condition of the unit shall be inspected. The Contractor shall also perform an annual 80% 4-hour load bank testing and shall record items including, but not limited to, oil pressure, water temperature, voltage, voltage frequency. The load bank testing shall be performed with no interruption of normal power supply and only during the hours specified by each site. This location shall receive four (4) inspections per year: May, November, February, August (one [1] Annual, one [1] Semi-Annual, and two [2] quarterly inspections). Oil Analysis upon request.

5. Telephone Diagnostics. If an "emergency repair" is required by the facility, the Contractor should first contact the facility personnel and see if the problem can be corrected before dispatching a technician to the facility.

6. Invoicing. Contractors shall bill for each site with itemized lists on all invoices; this shall include, but not be limited to, the following items:

- a. Arrival times/ length of time at each site;
- b. Verification from facility personnel that work was completed satisfactorily;
- c. A complete list of all installed items to include part numbers and cost;
- d. Break down of Straight Time hours and Overtime hours;
- e. Mileage only, in accordance with Section IX., paragraph F.

X. PREVENTIVE MAINTENANCE REQUIRED TASKS FOR GHQ FACILITY GENERATOR SETS (1970 West Broad Street, 1952 West Broad Street and 1583 Alum Creek Drive):

Quarterly Service

During a Quarterly visit, service technicians will perform the following:

Cooling System

1. Visual Inspection of Radiator/Heat Exchange for leaks, damage and obstruction
2. Add Coolant (up to four gallons) to bring the coolant to correct level
3. Inspect condition of radiator cap, gasket and sealing surface
4. Visual Inspection of water pump and cooling system gaskets for leaks
5. Inspect belts for cracking and fraying
6. Check jacket water heater(s) for proper operation and adjust thermostat setting as needed
7. Check belt tension
8. Inspect flexible water connections for crackling, leaks and pliability

Lubrication System

1. Add crankcase oil (up to two gallons of oil meeting or exceeding manufacturer's specifications, such as API CH-4, CG-4, CF-4 or Natural Gas oil if spark ignited) to bring the oil to its correct level
2. Inspect Oil heater for proper operation and leaks
3. Check for excessive crankcase blow-by with engine running
4. Visual inspection front and rear crankshaft seals and lubrication system gaskets for leaks

SPECIFICATIONS (Cont'd.)

Fuel System

1. Inspect flexible fuel lines for cracking, leaks and pliability
2. Test day tank pump for proper operation and level
3. Operate fuel priming pump and check for proper operation and leaks
4. Drain water from water separator
5. Check fuel system for leaks
6. Check Governor Oil level in main fuel tank
7. Record fuel level in main fuel tank

Starting System

1. Top off electrolyte level
2. Check and record battery charger amperage
3. Check batter charger and adjust float rate for optimum battery performance and life
4. Check and record alternator for proper charge rate with engine running.
5. Check for proper cranking termination upon starting

Exhaust System

1. Inspect flexible exhaust coupling for cracks and excessive leakage
2. Check for abnormal exhaust characteristics with engine running (signs of wet stacking)
3. Inspect exterior of exhaust manifolds for oil/fuel slobber (signs of wet stacking)
4. Inspect exhaust rain protection and exhaust outlet screening

Air Intake System

Inspect air filters for plugging and deterioration

Installation

1. Make walk around inspection of complete installation
2. Inspect generator set vibration isolators and adjust as needed
3. Check for unit on- line capability in less than 10 seconds
4. Check for abnormal noise or vibration
5. Re-Check oil level with engine running
6. Re-Check for leaks with engine running
7. Check for proper operation of remote fan motors, thermostats, circulating pumps and solenoid valves
8. Check inlet and discharge louvers for proper operation with engine running and stopped

Control Panel

1. Operational check of illumination and safety lamps
2. Check proper operation of engine and generator instruments with generator running
3. Adjust Governor Control for optimum performance and frequency
4. Adjust voltage regulator for proper voltage

Upon Completion of Service

1. Reset all controls to automatic
2. Set circuit breaker to correct position
3. Check fuel valves for correct position
4. Check voltage regulator is on and NOT tripped
5. Check battery charger is ON
6. Check day tank controls are ON
7. Louver controls are ON
8. Jacket Water Heater(s) are ON
9. Remote Radiator Fan Controls are ON
10. Auxiliary water pump controls are ON

Cooling System

Inspection of pulleys for excessive wear

SPECIFICATIONS (Cont'd.)

Fuel System

1. Inspection of steel fuel lines for cracks, leaks and proper line bracket support
2. Check the main tank for water (if accessible)

Starting System

1. Clean and apply corrosion inhibitor to the terminals of lead acid batteries as needed
2. Tighten battery cable connections as needed
3. Inspect and tighten starter motor(s), connections and wiring

Exhaust System

1. Drain water in exhaust moisture traps
2. Inspect exhaust manifold(s) for broken or missing hardware

Air Intake System

1. Test air cleaner indicator
2. Check all air intake piping for damage and loose connections

Semi-Annual Service

During a semi-annual visit, service technicians will perform the services listed in the quarterly visits as well as the following:

Cooling System

1. Analyze coolant for proper antifreeze percentage
2. Analyze coolant conditioner level and add additional supplemental coolant additive (SCA) as needed
3. Tighten hose clamps as needed
4. Lubricate fan drive with Caterpillar bearing lubricant for high speed applications and temperatures:
-30 degrees Fahrenheit to 325 degrees Fahrenheit

Lubrication System

1. Check crankcase breather, inspect hose and connections
2. Take oil sample for "Caterpillar Scheduled Oil Sampling Program (S.O.S), or the appropriate prime mover program depending on the facility

Fuel System

1. Clean primary fuel filter (if screen type)
2. Drain water and sediment from day tank (if accessible)
3. Clean Inlet filters for day tank
4. Test day tank alarms
5. Lubricate Governor Linkage

Starting System

1. Test and record battery cells' Electrolyte specific gravity
2. Check and record battery voltage dip level during over crank test for minimum voltage required to maintain controls during start-up

Air Intake System

1. Inspection of air cleaner seal for pliability and sealing
2. Inspection of turbocharger for excessive end play clearance (if accessible) and seal leakage

SPECIFICATIONS (Cont'd.)

Generator and Voltage Regulator

1. Check rotor air gap for correct clearance
2. Inspection of rotor and stator for damage and excessive oil or dirt build-up
3. Inspection of coupling and guards for loose or missing parts
4. Check tightness of generator leads and voltage regulator control wiring
5. Strap and tape any wiring or generator leads that have rubbing and /or worn insulation
6. Inspect brushes and slip rings or rotating rectifier
7. Clean and adjust voltage droop potentiometer
8. Inspect exciter field
9. Lubricate generator bearing with bearing lubricant for high speed applications and temperatures -10 degrees Fahrenheit to 325 degrees Fahrenheit

Control Panel

1. Check for and tighten loose terminals on the generator set and the generator control panel
2. Check tightness of relays in the generator control panel
3. Inspect for excessive dirt accumulation and clean as needed
4. Test auto-start system
5. Test safeties and pre-alarms on control and annunciator panels

Annual Service

During the annual visit, service technicians will perform the services listed in the Quarterly, and Semi-Annual visits as applicable per the specifications listed in this section and the previous section, as well as the following additional steps:

1. Change oil filters
2. Change primary and secondary fuel filters
3. Change engine oil (using oil meeting or exceeding manufacturer's specifications, such as; API CH-4, CG-4, CF-4 or Natural Gas Oil if Sparked Ignited)
4. Legally dispose of waste oil and filters
5. Replace inlet filter for day tank
6. Load Bank Testing
7. All additional tasks listed in the contract for annual checks.

After each visit, Contractor shall send a detailed follow-up report.

XI. SERVICE CENTER LOCATIONS:

All Bidders shall include in their ITB response, a listing of their service center locations that will be assigned to provide regularly scheduled and emergency services under any resultant contract. If a Bidder proposes multiple service center locations, the specific center which will be responsible for each Contract District must be identified in the Bid response.

XII. PARTS DISCOUNT:

Replacement parts shall be invoiced at the discounted rate from List Price quoted in the ITB. The State reserves the right to request additional documentation from the Contractor to support his/her pricing for replacement parts. In the event that OSHP desires to purchase additional repair/replacement parts, Contractor shall provide same at the parts discount listed in this ITB. Any expenditure exceeding one thousand five hundred dollars (\$1500.00) for labor and parts will require prior approval from the OSHP Technology and Communications Commander and appropriate Facility Management office.

XIII. ENGINEERING CONSULTATION:

During the contract, the Contractor shall provide, without additional charges, engineering consultation upon request of the OSHP Technology and Communications Commander or appropriate Facility Management office. A technician that is intimately familiar with the facility and equipment shall provide this consultation. The type of consultation shall be determined by the OSHP Technology and Communications Commander or Facility Management office, and may include problem solving, recommendations, specifications, drawings, and written reports.

SPECIFICATIONS (Cont'd.)

XIV. WORKMANSHIP - RESPONSIBILITY

- A. All labor performed on this contract shall be first class, and the Contractor shall be responsible for the quality of work as well as obtaining all necessary permits, and shall pay all costs connected with same.
- B. The Contractor shall be responsible for the acts or neglect of his employees when performing work under this contract. The Contractor's employees shall observe the rules and regulations of the facility when engaged in work under this contract on the facility's premises and those adjacent private or public properties.
- C. Upon completion of an inspection, the Contractor's team shall leave the systems in satisfactory operation; or, if not in operation, the team shall so inform the facility, explain why it is inoperative, and what must be done to put it into satisfactory operation.
- D. The Contractor shall guarantee his workmanship and material for a period of one (1) year from the date of acceptance by the facility and shall promptly remedy, at his expense, all defects due thereto which become evident during the guarantee period, and pay all expenses for any damage to other systems or structures resulting from work on the generator sets and associated systems.
- E. The Contractor shall be responsible for having a current Material Safety Data Sheet (MSDS) for any chemical that the Contractor brings onto facility grounds for the purpose of this contract (ref. OSHA Standard CFR 1910.1200). A copy of this MSDS shall be given to the facility contact person prior to using the chemical.
- F. Removal and proper disposal of all material, including, but not limited to, oil, coolant, fluids and parts, shall be the responsibility of the Contractor.

XV. PROVIDING RENTAL GENERATOR(S)

Contractor shall provide rental generator(s) within twenty-four (24) hours notice after having received the request from the OSHP or EMA to provide said generator. Contractor's rental rates shall be those currently in effect at the time of the rental. If Contractor does not have in stock the type and size of generator that is needed for rental, Contractor will secure generator from a third party and provide said rental generator at a rate not to exceed a twenty percent (20%) markup based upon cost.

Contractor shall deliver and install the rental generator to the OSHP or EMA site, and shall ensure the unit is set in place with required equipment and operational instructions given to the OSHP Post Commander, or his/her designee, or the listed contract person. Rental generator shall be equivalent to the size and output range for each unit replaced.

The state agrees to pay only the actual cost plus a percentage markup not to exceed twenty percent (20%) for the third-party rental generator, and may request a copy of the invoice from the third-party for documentation.

XVI. DISTRICTS

District	Counties
Northwest	Williams, Defiance, Paulding, Van Wert, Mercer, Fulton, Henry, Putnam, Allen, Auglaize, Shelby, Lucas, Wood, Hancock, Hardin, Logan, Ottawa, Sandusky, Seneca, Wyandot, Marion, Union
Northeast	Ashtabula, Trumbull, Mahoning, Columbiana, Lake, Geauga, Portage, Stark, Cuyahoga, Summit, Lorain, Medina, Wayne, Holmes, Erie, Huron, Ashland, Richland, Knox, Crawford, Morrow, Delaware
Southwest	Darke, Miami, Champaign, Clark, Madison, Preble, Montgomery, Greene, Fayette, Pickaway, Butler, Warren, Clinton, Highland, Ross, Hamilton, Clermont, Brown, Adams, Pike, Scioto
Southeast	Carroll, Jefferson, Tuscarawas, Harrison, Belmont, Monroe, Coshocton, Guernsey, Noble, Licking, Muskingum, Morgan, Washington, Fairfield, Perry, Athens, Hocking, Vinton, Meigs, Jackson, Gallia, Lawrence
Central	Franklin

PRICE SCHEDULE

ANNUAL EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR					
ITEM I.D. : 12994					
NORTHWEST CONTRACT DISTRICT			CONTRACTOR: JD POWER SYSTEMS		
	SCHEDULED SERVICE	EMERGENCY SERVICE			
	FLAT RATE (USED FOR ALL LOCATIONS IN THIS DISTRICT)	HOURLY RATE (STRAIGHT TIME) TIME ON-SITE ONLY	HOURLY RATE (OVERTIME) TIME ON-SITE ONLY	MILEAGE RATE, ONE-WAY	REPLACEMENT PARTS (DISCOUNT FROM LIST PRICE)
FIRST YEAR 1/01/08 through 12/31/08	\$525.00 /Location	\$65.00 /hour	\$97.50 /hour	\$1.00 /mile	10%discount
SECOND YEAR 1/01/09 through 12/31/09	\$550.00 /Location	\$66.50 /hour	\$99.75 /hour	\$1.00 /mile	10%discount

Bidder's service location address which will be responsible for service in the Northwest Contract District:

JD Power Systems
 219 Columbus-Sandusky Rd.
 Marion, OH 43302

Using the above rates, and the service center location to be assigned for this Contract District on any resultant contract, calculate the service charges for the following scenario site service visits:

NORTHWEST DISTRICT SCENARIO SERVICE SITE: OSHP POST #20, 2350 BALTIMORE ROAD, DEFIANCE, OH 43512

SERVICE TYPE	TIME ON SITE AND COST	ONE-WAY DISTANCE FROM BIDDER'S SERVICE CENTER TO SCENARIO SITE	TOTAL ONE-WAY MILEAGE COST	DISCOUNTED COST FOR \$300.00 REPLACEMENT PARTS	TOTAL COST FOR THIS SERVICE
(First year) EMERGENCY	2.0 HOURS STRAIGHT TIME \$130.00	110 miles	\$110.00	\$270.00	\$510.00
(First Year) EMERGENCY	3.0 HOURS OVERTIME \$292.50	110 miles	\$110.00	\$270.00	\$672.50
(Second Year) EMERGENCY	4.0 HOURS STRAIGHT TIME \$266.00	110 miles	\$110.00	\$270.00	\$646.00
(Second Year) EMERGENCY	5.0 HOURS OVERTIME \$498.75	110 miles	\$110.00	\$270.00	\$878.75

PRICE SCHEDULE

ANNUAL EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR					
ITEM I.D. : 12976					
NORTHEAST CONTRACT DISTRICT			CONTRACTOR: KRAFT POWER CORPORATION		
	SCHEDULED SERVICE	EMERGENCY SERVICE			
	FLAT RATE (USED FOR ALL LOCATIONS IN THIS DISTRICT)	HOURLY RATE (STRAIGHT TIME) TIME ON-SITE ONLY	HOURLY RATE (OVERTIME) TIME ON-SITE ONLY	MILEAGE RATE, ONE-WAY	REPLACEMENT PARTS (DISCOUNT FROM LIST PRICE)
FIRST YEAR 1/01/08 through 12/31/08	\$580.00 /Location	\$70.00 /hour	\$105.00 /hour	\$1.75 /mile	10%discount
SECOND YEAR 1/01/09 through 12/31/09	\$610.00 /Location	\$73.50 /hour	\$110.25 /hour	\$1.80 /mile	10%discount

Bidder's service location address which will be responsible for service in the Northeast Contract District:

Kraft Power Corporation
 608 Cleveland Avenue, SW
 Canton, OH 44702

Using the above rates, and the service center location to be assigned for this Contract District on any resultant contract, calculate the service charges for the following scenario site service visits:

NORTHEAST DISTRICT SCENARIO SERVICE SITE: OSHP POST #85, 1786 Dover Road, Wooster, OH 44691

SERVICE TYPE	TIME ON SITE AND COST	ONE-WAY DISTANCE FROM BIDDER'S SERVICE CENTER TO SCENARIO SITE	TOTAL ONE-WAY MILEAGE COST	DISCOUNTED COST FOR \$300.00 REPLACEMENT PARTS	TOTAL COST FOR THIS SERVICE
(First year) EMERGENCY	2.0 HOURS STRAIGHT TIME \$140.00	34 miles	\$59.50	\$270.00	\$469.50
(First Year) EMERGENCY	3.0 HOURS OVERTIME \$315.00	34 miles	\$59.50	\$270.00	\$644.50
(Second Year) EMERGENCY	4.0 HOURS STRAIGHT TIME \$441.00	34 miles	\$61.20	\$270.00	\$772.20
(Second Year) EMERGENCY	5.0 HOURS OVERTIME \$551.25	34 miles	\$61.20	\$270.00	\$882.45

PRICE SCHEDULE

ANNUAL EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR					
ITEM I.D.: 12995					
SOUTHWEST CONTRACT DISTRICT			CONTRACTOR: JD POWER SYSTEMS		
	SCHEDULED SERVICE	EMERGENCY SERVICE			
	FLAT RATE (USED FOR ALL LOCATIONS IN THIS DISTRICT)	HOURLY RATE (STRAIGHT TIME) TIME ON-SITE ONLY	HOURLY RATE (OVERTIME) TIME ON-SITE ONLY	MILEAGE RATE, ONE-WAY	REPLACEMENT PARTS (DISCOUNT FROM LIST PRICE)
FIRST YEAR 1/01/08 through 12/31/08	\$525.00 /Location	\$65.00 /hour	\$97.50 /hour	\$1.00 /mile	10% discount
SECOND YEAR 1/01/09 through 12/31/09	\$550.00 /Location	\$66.50 /hour	\$99.75 /hour	\$1.00 /mile	10% discount

Bidder's service location address which will be responsible for service in the Southwest Contract District:

JD Power Systems
 7550 US 68 N.
 Wilmington, OH 45177

Using the above rates, and the service center location to be assigned for this Contract District on any resultant contract, calculate the service charges for the following scenario site service visits:

SOUTHWEST DISTRICT SCENARIO SERVICE SITE: OSHP POST #8, 717 East State Street, Georgetown, OH 45121

SERVICE TYPE	TIME ON SITE AND COST	ONE-WAY DISTANCE FROM BIDDER'S SERVICE CENTER TO SCENARIO SITE	TOTAL ONE-WAY MILEAGE COST	DISCOUNTED COST FOR \$300.00 REPLACEMENT PARTS	TOTAL COST FOR THIS SERVICE
(First year) EMERGENCY	2.0 HOURS STRAIGHT TIME \$130.00	51miles	\$51.00	\$270.00	\$451.00
(First Year) EMERGENCY	3.0 HOURS OVERTIME \$292.50	51miles	\$51.00	\$270.00	\$613.50
(Second Year) EMERGENCY	4.0 HOURS STRAIGHT TIME \$266.00	51miles	\$51.00	\$270.00	\$587.00
(Second Year) EMERGENCY	5.0 HOURS OVERTIME \$498.75	51miles	\$51.00	\$270.00	\$819.75

PRICE SCHEDULE

ANNUAL EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR					
ITEM I.D.: 12996					
SOUTHEAST CONTRACT DISTRICT			CONTRACTOR: JD POWER SYSTEMS		
	SCHEDULED SERVICE	EMERGENCY SERVICE			
	FLAT RATE (USED FOR ALL LOCATIONS IN THIS DISTRICT)	HOURLY RATE (STRAIGHT TIME) TIME ON-SITE ONLY	HOURLY RATE (OVERTIME) TIME ON-SITE ONLY	MILEAGE RATE, ONE-WAY	REPLACEMENT PARTS (DISCOUNT FROM LIST PRICE)
FIRST YEAR 1/01/08 through 12/31/08	\$525.00 /Location	\$65.00 /hour	\$97.50 /hour	\$1.00 /mile	10% discount
SECOND YEAR 1/01/09 through 12/31/09	\$550.00 /Location	\$66.50 /hour	\$99.75 /hour	\$1.00 /mile	10% discount

Bidder's service location address which will be responsible for service in the Southeast Contract District:

JD Power Systems
 1200 Delmont Road
 Lancaster, OH 43130

Using the above rates, and the service center location to be assigned for this Contract District on any resultant contract, calculate the service charges for the following scenario site service visits:

SOUTHEAST DISTRICT SCENARIO SERVICE SITE: OSHP POST #5, 13600 Della Drive, Athens, OH 45701

SERVICE TYPE	TIME ON SITE AND COST	ONE-WAY DISTANCE FROM BIDDER'S SERVICE CENTER TO SCENARIO SITE	TOTAL ONE-WAY MILEAGE COST	DISCOUNTED COST FOR \$300.00 REPLACEMENT PARTS	TOTAL COST FOR THIS SERVICE
(First year) EMERGENCY	2.0 HOURS STRAIGHT TIME \$130.00	52 Miles	\$52.00	\$270.00	\$452.00
(First Year) EMERGENCY	3.0 HOURS OVERTIME \$292.50	52 Miles	\$52.00	\$270.00	\$614.50
(Second Year) EMERGENCY	4.0 HOURS STRAIGHT TIME \$266.00	52 Miles	\$52.00	\$270.00	\$588.00
(Second Year) EMERGENCY	5.0 HOURS OVERTIME \$498.75	52 Miles	\$52.00	\$270.00	\$820.75

Price Schedule

ANNUAL EMERGENCY POWER GENERATOR INSPECTION, TESTING, PREVENTIVE MAINTENANCE AND REPAIR								
ITEM I.D.: 12997								
CENTRAL CONTRACT DISTRICT				CONTRACTOR: CUMMINS BRIDGEWAY LLC *				
	SCHEDULED SERVICE				EMERGENCY SERVICE			
	FLAT RATE FOR 1000 KW GENSET							
	EOC/DHQ	ODPS (Shipley)	FLAT RATE FOR 500 KW GENSET	FLAT RATE FOR 50 KW GENSET	HOURLY RATE (STRAIGHT TIME) TIME ON-SITE ONLY	HOURLY RATE (OVERTIME) TIME ON-SITE ONLY	MILEAGE RATE, ONE-WAY	REPLACEMENT PARTS (Discount from List Price)
FIRST YEAR 1/01/08 through 12/31/08	\$2,832.00 /ea	\$2,832.00 /ea	\$908.00 each	\$708.00 each	\$100.00 /hour	\$150.00 /hour	\$0.00 mile	10% discount
SECOND YEAR 1/01/09 through 12/31/09	\$2,900.00 /ea	\$2,900.00 /ea	\$935.00 each	\$725.00 each	\$103.00 /hour	\$154.50 /hour	\$0.00/mile	10 % discount

CENTRAL CONTRACT DISTRICT OIL ANALYSIS	
COST PER ANALYSIS FOR ONE GENSET	
FIRST YEAR 1/01/08 through 12/31/08	\$40.00 /Each
SECOND YEAR 1/01/09 through 12/31/09	\$42.00 /Each

* Effective February 1, 2011, Cummins Bridgeway LLC will no longer offer services for DPS037. Facilities shall utilize direct purchase authority.

Using the rates quoted on Price Schedule page 16, and the service center location to be assigned for this Contract District on any resultant contract, calculate the service charges for the following scenario site service visits:

CENTRAL DISTRICT SCENARIO SERVICE SITE: ODPS Shipley Building, 1970 W. Broad St., Columbus, OH 43223 *					
SERVICE TYPE	TIME ON-SITE AND COST	ONE-WAY DISTANCE FROM BIDDER'S SERVICE CENTER TO SCENARIO SITE	TOTAL ONE-WAY MILEAGE COST	DISCOUNTED COST FOR \$300.00 REPLACEMENT PARTS	TOTAL COST FOR THIS SERVICE
(First year) EMERGENCY	2.0 HOURS STRAIGHT TIME \$200.00	0 miles	\$0.00	\$270.00	\$470.00
(First Year) EMERGENCY	3.0 HOURS OVERTIME \$450.00	0 miles	\$0.00	\$270.00	\$720.00
(Second Year) EMERGENCY	4.0 HOURS STRAIGHT TIME \$412.00	0 miles	\$0.00	\$270.00	\$682.00
(Second Year) EMERGENCY	5.0 HOURS OVERTIME \$772.50	0 miles	\$0.00	\$270.00	\$1,042.50

* Effective February 1, 2011, Cummins Bridgeway LLC will no longer offer services for DPS037. Facilities shall utilize direct purchase authority.

CONTRACTOR INDEX

CONTRACTOR AND TERMS:

000003184
* Cummins Bridgeway LLC
4000 Lyman Drive
Hilliard, OH 43026



CONTRACTOR'S CONTACT: Ramon Knieper,

REMIT TO:

Cummins Bridgeway LLC
21810 Clessie Court
New Hudson, MI 48165

BID CONTRACT NO.: OT905108-1

DELIVERY: per ITB schedule

TERMS: Net 30 Days

Toll Free: (800) 969-3966

Telephone: (614) 771-1000

FAX: (614) 527-2839

E-Mail: ramon.s.knieper@cummins.com

Receiving Purchase Order: Fax

CONTRACTOR AND TERMS:

0000174322
JD Power Systems LLC
4000 Gantz Road, Suite A
Grove City, OH 43123



CONTRACTOR'S CONTACT: Dave Siegesmund,

BID CONTRACT NO.: OT905108-5

DELIVERY: per ITB schedule

TERMS: Net 30 Days

Toll Free: (800) 659-5646

Telephone: (614) 317-9394

FAX: (614) 801-0439

E-Mail: davesiegesmund@jdequipment.com

Receiving Purchase Order: E-Mail

CONTRACTOR AND TERMS:

0000001530
Kraft Power Corporation
4039 Millennium Blvd. SE
Massillon, OH 44646



CONTRACTOR'S CONTACT: Priscilla Kovacsiss

REMIT TO:

Kraft Power Corporation
P.O. Box 2189
Woburn, MA 01888-0389

BID CONTRACT NO.: OT905108-4

DELIVERY: per ITB schedule

TERMS: Net 30 Days

Toll Free: (800) 835-5254

Telephone: (330) 830-4158

FAX: (330) 455-0798

E-Mail: pkovacsiss@kraftpower.com

Receiving Purchase Order: E-Mail

* Effective February 1, 2011, Cummins Bridgeway will no longer offer services for DPS037. Agencies shall utilize direct purchase authority.

Appendix A

Gen. No. / County	Generator ID	OSHP Dist.	OSHP Post #	Location	Model	Serial Number
1 Allen	G0102L1	1	2	LIMA 2005 East 4th St. Lima, OH 45804 Phone: (419) 228-2421	OLYMPIAN G45F1 / 109647 27	109647 27
2 Defiance	G0120L1	1	20	DEFIANCE 2350 Baltimore Road Defiance, OH 43512 Phone: (419) 784-1025	KOHLER 70RZ282 PB703389-A 70 KVA GEN	
3 Hancock	G0132L1	1	32	FINDLAY 3201 N. Main Street Findlay, OH 45840 Phone: (419) 423-1414	ONAN 85GGHG/4960985 E010241392	F010250886
4 Fulton	G0148L1	1	48	TOLEDO 10391 Airport Highway Swanton, OH 43558 Phone: (419) 865-5544	KOHLER 30RZ62 30 KVA GEN	361518
5 Wood	G0187L1	1	87	WALBRIDGE 12891 Middleton Pike Bowling Green, OH 43402 Phone: (419) 352-2481	KOHLER 33RZ282 33 KVA GEN	302498
6 Hancock	G0100L1	1	DHQ	FINDLAY - DHQ 3201 N. Main Street Findlay, OH 45840 Phone: (419) 423-1414	GENERAC 94A04071-S	2015440
7 Hancock	G0100P1 (Portable)	1	DHQ	FINDLAY - DHQ 3201 N. Main Street Findlay, OH 45840	HONDA EG2200X	1914867
8 Hancock	G0100P2 (Portable)	1	DHQ	FINDLAY - DHQ 3201 N. Main Street Findlay, OH 45840	HONDA	1786449
9 Hancock	G0100P3 (Portable)	1	DHQ	FINDLAY - DHQ 3201 N. Main Street Findlay, OH 45840	HONDA	1893786
10 Crawford	G0217L1	2	17	BUCYRUS 3665 SR4 Bucyrus, OH 44820 Phone: (419) 562-8040	KOHLER 70RZ81 70 KVA GEN	109141
11 Erie	G0222L1	2	22	SANDUSKY 511 Fremont Road Sandusky, OH 44870 Phone: (419) 625-6565	KOHLER 100RZG	747212
12 Huron	G0239L1	2	39	NORWALK 300 S. Norwalk Road Norwalk, OH 44857 Phone: (419) 668-3711	KOHLER 70RZ282 70 KVA GEN	254497
13 Marion	G0251L1	2	51	MARION 2284 Marion-Upper Sandusky Rd. Marion, OH 43302 Phone: (419) 383-2181	KOHLER LSG-8751-6005-A FORD 460 V-8	3384F-13- RK
14 Richland	G0270L1	2	70	MANSFIELD 2255 S. Main Street Mansfield, OH 44907 Phone: (419) 756-2222	KOHLER 30RZ62 30 KVA	361513

Appendix A

16 Sandusky	G0272L1	2	72	FREMONT 2226 Commerce Drive Fremont, OH 43420 Phone: (419) 332-8246	SPECTRUM DETROIT DIESEL 60GSG	712767
17 Crawford	G0217P1 (Portable)	2	DHQ	BUCYRUS 3665 S.R. 4 Bucyrus, OH 44820 Phone: (419) 562-8040	HONDA EG2200X	178648
18 Crawford	G0217P2 (Portable)	2	DHQ	BUCYRUS 3665 S.R. 4 Bucyrus, OH 44820 Phone: (419) 562-8040	HONDA EG2200X	1914871
19 Ashland	G0303L1	3	3	ASHLAND 805 US250 Ashland, OH 44805 Phone: (419) 289-0911	KOHLER 33RZ2282 33 KVA GEN	285910
20 Lorain	G0347L1	3	47	ELYRIA 38000 Cletus Drive Elyria, OH 44035 Phone: (440) 323-5494	KOHLER 30RZ62 30 KVA GEN	39003
21 Medina	G0352L1	3	52	MEDINA 3149 Frantz Road Medina, OH 44256 Phone: (330) 725-4921	KOHLER 30RZ62	361516
23 Stark	G0376P1 (Portable)	3	76	CANTON 4710 Shuffel Drive NW North Canton, OH 44720 Phone: (330) 433-6200	HONDA EG2200X 2 2KW GEN	1914874
24 Stark	G0377L1	3	77	CANTON 4710 Shuffel Drive NW North Canton, OH 44720 Phone: (330) 433-6200	KOHLER 35R262 35 KV GENER	375663
25 Wayne	G0385L1	3	85	WOOSTER 1786 Dover Road Wooster, OH 44691 Phone: (330) 264-0575	KOHLER 35RZ62	604019
27 Stark	G03L1	3	DHQ	MASSILLION-DHQ 4300 Lincoln Way West Massillon, OH 44647 Phone: (330) 833-1055	KOHLER 30RZ01	45379
28 Ashtabula	G0404L1	4	4	ASHTABULA 4860 N. Ridge Road W Ashtabula, OH 44004 Phone: (440) 969-1155	DETROIT 606SG 60K GENERATOR	606SG

Appendix A

30 Columbiana	G0415L1	4	15	LISBON 9423 SR45 Lisbon, OH 44432 Phone: (330) 424-7783	KOHLER 30RZ01 30 KVA GEN	45373
31 Geauga	G0428L1	4	28	CHARDON 530 Center Street Chardon, OH 44024 Phone: (440) 286-6612	DETROIT 60GS6 60K GENERATOR	606SG
33 Mahoning	G0450L1	4	50	CANFIELD 500 S. Broad Street Canfield, OH 44406 Phone: (330) 533-6866	ONAN 30 0EK-15R 30 KVA GEN	874861214
34 Portage	G0467L1	4	67	RAVENNA 6259 SR14 Ravenna, OH 44266 Phone: (330) 297-1441	KOHLER 35RZ62 35 KVA GEN	315664
35 Trumbull	G0478L1	4	78	WARREN 3424 SR422/PO Box 220 Southington, OH 44470 Phone: (330) 898-2311	ONAN 75 0DVB-15R/2982929 75 KVA GEN	H860836613
36 Auglaize	G0506L1	5	6	WAPAKONETA Route 5 - Wapak-Fisher Road Wapakoneta, OH 45895 Phone: (419) 738-8010	ONAN 70ENL32270E FORD ENGINE	L880185345
37 Clark	G0512L1	5	12	SPRINGFIELD 4201 Gateway Blvd. Springfield, OH 45502 Phone: (937) 323-9781	KOHLER 30RZ62 GENERATPR	361512
38 Miami	G0555L1	5	55	PIQUA 401 West US36 E Piqua, OH 45356 Phone: (937) 773-1131	ONAN 70 OEN-15R/25661D FORD ENGINE	A830647591
39 Montgomery	G0557L1	5	57	DAYTON 400 Smith Drive Clayton, OH 45322 Phone:	KOHLER 60 RZG GEN MOTOR	712242
40 Union	G0580L1	5	80	MARYSVILLE 22600 Northwest Parkway Marysville, OH 43040 Phone: (937) 644-8811	KOHLER 70RZ282 FORD ENGINE	LSG875160 05
42 Miami	G0500P1 (Portable)	5	DHQ	PIQUA - DHQ 401 West U.S. 36 E. Piqua, OH 45356 Phone: (937) 773-1131	HONDA EG2200X HONDA ENGINE	1893791
43 Miami	G0500P2 (Portable)	5	DHQ	PIQUA - DHQ 401 West U.S. 36 E. Piqua, OH 45356 Phone: (937) 773-1131	HONDA EG2200X HONDA ENGINE	1786454

Appendix A

44 Miami	G0500P3 (Portable)	5	DHQ	PIQUA - DHQ 401 West U.S. 36 E. Piqua, OH 45356 Phone: (937) 773-1131	HONDA EG2200X HONDA ENGINE	2010612
46 Fairfield	G0623L1	6	23	LANCASTER 1125 Ety Road NW Lancaster, OH 43130 Phone: (740) 654-1523	KOHLER 33RZ262 GENERATOR	302425
47 Licking	G0645L1	6	45	GRANVILLE 3855 Outville Road Granville, OH 43023 Phone: (740) 927-0065	KOHLER 35RZ62 GENERATOR	398537
48 Madison	G0649L1	6	49	W JEFFERSON 1485 W. Main Street West Jefferson, OH 43162 Phone: (740) 879-7626	DETROIT DIESEL 35GS60	
49 Morrow	G0659L1	6	59	MT GILEAD 3980 County Road 172 Mt. Gilead, OH 43338 Phone: (419) 768-3955	ONAN 70 0EN-15R/1246D GENERATOR	8840696326
56 Licking	G0600R1	6	DHQ	COLUMBUS-JOHNSTOWN TOWER Columbus, OH 43235 Phone: (614) 799-9241	KOHLER 30RZ62 GENERATOR	371239 SPEC PA- 185090-62L
57 Belmont	G0707L1	7	7	ST CLAIRSVILLE 51400 National Road St. Clairsville, OH 43950 Phone: (740) 695-0915	KOHLER 33RZ26 ENGINE	CSG649160 05F

Appendix A

59 Guernsey	G0730L1	7	30	CAMBRIDGE 7051 Glenn Highway Cambridge, OH 43725 Phone: (740) 439-1388		
60 Guernsey	G0730P1 (Portable)	7	30	CAMBRIDGE 7051 Glenn Highway Cambridge, OH 43725 Phone: (740) 439-1388	HONDA EG2200X GENERATOR	2011771
61 Guernsey	G0730R1	7	30	CAMBRIDGE Cambridge, OH 43725 Phone: (740) 439-1388	KOHLER 15RM62 / PURCHASED 1972 GENERATOR	485110
62 Jefferson	G0741L1	7	41	STEUBENVILLE 1377 Cadiz Road Wintersville, OH 43952 Phone: (740) 264-1641	KOHLER 33RZ262 FORD ENGINE	CSG649160 05F
63 Jefferson	G0784L1	7	41	STEUBENVILLE 1377 Cadiz Road Wintersville, OH 43952 Phone: (740) 264-1641	KOHLER 12RZ62 FORD ENGINE	VSG413160 05A/8052K0 9RB
64 Muskingum	G0760L1	7	60	ZANESVILLE 3760 East Pike Zanesville, OH 43701 Phone: (740) 453-0541	KOHLER 33RZ262 FORD ENGING	MODEL CSG6491 SER 6005-F
66 Tuscarawas	G0779L1	7	79	NEW PHILADELPHIA 2454 E. High Avenue New Philadelphia, OH 44663 Phone: (330) 339-1103	ONAN 70ENC GENERATOR	F920473119
67 Tuscarawas	G0779R1	7	79	NEW PHILADELPHIA New Philadelphia, OH 44663 Phone: (330) 339-1103	KOHLER 10RY62 GENERATOR	290706
70 Brown	G0808L1	8	8	GEORGETOWN 717 East State Street Georgetown, OH 45121 Phone: (937) 378-6191	ONAN 30 0EK-3R/11223M 30 KVA GEN	3790421447
73 Butler	G0809L1	8	9	HAMILTON 4751 Hamilton-Middletown Road Hamilton, OH 45011 Phone: (513) 863-4606	ONAN 30 0EK-3R/23980M 30 KVA GEN	1 810590894

Appendix A

74 Clermont	G0813L1	8	13	BATAVIA 1000 Hospital Drive Batavia, OH 45108 Phone: (513) 732-1510	ONAN 15 0 RJC 3-R/7802S 15 KVA GEN	1 271 329 686
75 Clinton	G0814L1	8	14	WILMINGTON 950 Rombach Avenue Wilmington, OH 45177 Phone: (937) 382-2551	KOHLER 30RZ61 30 KVA GEN	45384
76 Clinton	G0814P1 (Portable)	8	14	WILMINGTON 950 Rombach Avenue Wilmington, OH 45177 Phone: (937) 382-2551	HONDA EG2200X 2 2 KVA GEN	2011718
77 Greene	G0829L1	8	29	XENIA 517 Union Road Xenia, OH 45385 Phone: (937) 372-7671	KOHLER 15R62 15 KVA GEN	319350
79 Warren	G0883L1	8	83	LEBANON 184 Nelson Road Lebanon, OH 45036 Phone: (513) 932-4444	KOHLER 30RZ62 30 KVA GEN	361515
80 Athens	G0905L1	9	5	ATHENS 13600 Della Drive Athens, OH 45701 Phone: (740) 593-6611	KOHLER 50RZ 55 KW	673275
81 Gallia	G0927L1	9	27	GALLIPOLIS 396 Jackson Pike Gallipolis, OH 45631 Phone: (740) 446-2433	KOHLER 115AZ82 PA-704964-A	GENERATOR 370992
82 Gallia	G0927R1	9	27	MOUND HILL Gallipolis, OH 45631 Phone: (740) 446-2433	KOHLER 12RY 12KVA	762171
83 Jackson	G0944P2 (Portable)	9	40	JACKSON 10179 Chillicothe Pike Jackson, OH 45640 Phone: (740) 286-4141	HONDA EG2200X 2KVA HONDA GEN	1786468
84 Jackson	G0940L1	9	40	JACKSON 10179 Chillicothe Pike Jackson, OH 45640 Phone: (740) 286-4141	KOHLER 100RZ62 85KVA GEN	174099
85 Jackson	G0940P1 (Portable)	9	40	JACKSON 10179 Chillicothe Pike Jackson, OH 45640 Phone: (740) 286-4141	HONDA EG2200XX HONDA-2KVA GEN	GX140- 1714208
86 Jackson	P0940P3 (Portable)	9	40	JACKSON 10179 Chillicothe Pike Jackson, OH 45640 Phone: (740) 286-4141	HONDA EG2200X 2KVA HONDA GEN	1761282
87 Lawrence	G0944L1	9	44	IRONTON 126 Private Rd, 1336 CR60 South Point, OH 45680 Phone: (740) 377-4311	DETROIT-DESL 60GSG 60 KV GENERATOR	712769
88 Lawrence	G0944R1	9	44	IRONTON South Point, OH 45680 Phone: (740) 377-4311	KOHLER 12RY62 12KVA KOHLER	452207

Appendix A

89 Ross	G0971L1	9	71	CHILLICOTHE 201 Hospital Road Chillicothe, OH 45601 Phone: (740) 775-7770	DETROIT 60GSG 12 KVA	714363
90 Scioto	G0973L1	9	73	PORTSMOUTH 7611 US23N Lucasville, OH 45648 Phone: (740) 354-2888	KOHLER 60RZG 60KVA GEN	746826
92 Scioto	G0973R2	9	73	PORTSMOUTH Lucasville, OH 45648 Phone: (740) 354-2888	KOHLER 12K164231/12CS/12DS/2 3CB KOHLER 12 5K	K53038
93 Scioto	G0973R3	9	73	DUTCH RIDGE Lucasville, OH 45648 Phone: (740) 354-2888	KOHLER 20RZ262 GENERATOR	377592
94 Van Wert	2045760	1	81	VAN WERT 10234 Van Wert Decatur Rd. Van Wert, OH 45891 Phone: (419) 238-3055	KOHLER 80RZG (natural gas driven generator)	8P1L10553
95 Miami	n/a (Portable)	5	55	PIQUA 401 West U.S. 36 Piqua, OH 45356 Phone: (937) 773-1131	HONDA EB6500X	EALC10198 59
96 Miami	n/a (Portable)	5	55	PIQUA 401 West U.S. 36 Piqua, OH 45356 Phone: (937) 773-1131	HONDA EV3000	EZGH20234 1
97 Clinton	n/a (Portable)	8	14	WILMINGTON 950 Rombaugh Avenue Wilmington, OH 45177 Phone: (937) 382-2551	DAYTON 3W795	1282552

Appendix A

Central Contract District Sites:

EOC/DHQ 1500 Columbus Pike Columbus, OH 43235 Phone: (614) 889-7181 Contact: George (Bud) Newall		1000 KW Generator Model 1000 DFJD SN: F9405455405		3 Phase 277/480 Cummins 12 cylinder diesel Hours for service: 7:30 A.M. – 3:00 P.M.		
ODPS/Ohio State Highway Patrol 1970 West Broad Street Columbus, OH 43223 Phone: (614) 995-5437 Contact: Jeff Dubois		1000 KW Generator Model: 1000 DFJD SN: E970639652		3 Phase 277/480 Cummins 12 cylinder diesel Unit is to be serviced by certified Cummins Technician only. Unit receives four (4) inspections per year.		
ODPS/Center School 1952 West Broad Street Columbus, OH 43223 Phone: (614) 995-5437 Contact: Jeff Dubois		50 KW Generator Model: 50RZGB SN: 2090164 Kohler		3 Phase/60hz 277/480 Natural Gas		
Alum Creek Facility 1583 Alum Creek Drive Columbus, OH 43209 Phone: (614) 995-1995 Contact: Michael Vansuch		500 KW Generator Model: 500REOZVB SN: 2154224		3 phase Diesel		
Alum Creek Facility 1583 Alum Creek Drive Columbus, OH 43209 Phone: (614) 995-1995 Contact: Michael Vansuch		500 KW Generator Model: 500REOZVB SN: 2154225		3 phase Diesel		
Gen. No. / County	Generator ID	OSHP Dist.	OSHP Post #	Location	Model	Serial Number
51 Franklin	G0696P1 (Portable)	6	96	FAIRGROUNDS PD 717 East 17th Ave. Columbus, OH 43211 Phone: (614) 644-4050	HONDA EG2800X PORTABLE	
53 Franklin	G0600P1 (Portable)	6	DHQ	COLUMBUS – DHQ 2855 W. Dublin-Granville Rd Columbus, OH 43235 Phone: (614) 799-9241	HONDA EG2200X HONDA ENGINE	1914870
55 Franklin	G0600P3 (Portable)	6	DHQ	GENERATOR ON TRAILER 2855 W. Dublin-Granville Rd Columbus, OH 43235 Phone: (614) 799-9241	KOHLER 30K	

Appendix B



Ohio State Highway Patrol
(Emergency Generator Checklist)

Date: _____

Generator # _____

Post #: _____

Model # _____

Location: _____

Technician: _____

Annual Service to include:

1. Check coolant levels _____
2. Analyze coolant levels anti-freeze percentage _____
3. Inspect cooling system hoses _____
4. Tighten hose clamps as needed _____
5. Clean fuel filter _____
6. Clean air cleaner _____
7. Service belts as required _____
8. Check engine heater operation _____
9. Check generator set for fuel, oil and coolant leaks _____
10. Check air intakes and outlets _____
11. Check transfer tank operation _____
12. Drain exhaust line _____
13. Check battery charger operation and charge rate _____
14. Check battery electrolyte level and specific gravity _____
15. Check generator output and voltage and adjust as necessary _____
16. Emergency system operation with load transfer _____
17. Emergency system operation without load transfer _____
18. Frequency check/governor adjustment _____
19. Check transfer switch and accessory operation _____
20. Check engine alternator charge rates _____
21. Check engine and generator gauge and indicator operation _____
22. Check generator set controller (shutdown/emergency stop) _____
23. Lube, oil and filter change _____
24. Fuel filter change _____
25. Engine tune up/with parts _____
26. Load Bank Testing and Inspection. _____

SUMMARY OF AMENDMENTS

Amendment Number	Revision Date	Description
6	05/27/11	This amendment is issued to notify that this contract will expire on May 31, 2011 and will not be renewed. Agencies shall procure their requirements in accordance with their Direct Purchase Authority pursuant to Revised Code Section 125.05.
5	01/28/11	To notify that as a result of mutual agreement, this amendment is issued to renew the subject contract for an additional 4 months, effective February 1, 2011 through May 31, 2011. All other prices, terms and conditions remain unchanged. Effective February 1, 2011, Cummins Bridgeway LLC will no longer offer services for DPS037. Agencies shall utilize direct purchase authority in accordance with ORC 125.05.
4	01/07/11	To notify that DPS037 will not be renewed beyond 01/31/11 and all services will be covered under a new generator service contract.
3	12/21/10	To update contractor contact information and notify that as a result of unilateral agreement, this amendment is issued to renew the subject contract for an additional 30 days, effective January 1, 2011 through January 31, 2011. All other prices, terms and conditions remain unchanged.
2	10/05/09	Update to Contractor Index for JD Power Systems LLC
1	05/06/09	Update to Item I.D. No. for Southwest District, JD Power Systems; update to Contract Number for Kraft Power Corporation.